

**Summary of Sampling**

32 water samples were collected from 14 sources. All results are shown in Table 1.1.

**Table 1.1**

Sample ID	Sample Location Description	Fixture Type	Sample Type	Concentration
1a	Outside 1st Floor Maintenance Room	DF - Drinking Fountain	First Draw	ND
1b	Outside 1st Floor Maint. Rm - Bottle Filler	O - Other	First Draw	ND
1c	Outside 1st Floor Maintenance Room	DF - Drinking Fountain	Flush	ND
2a	Ag Hallway	DF - Drinking Fountain	First Draw	ND
2b	Ag Hallway	DF - Drinking Fountain	Flush	ND
3a	Lower Level Locker Room	DF - Drinking Fountain	First Draw	ND
3b	Lower Level Locker Room - Bottle Filler	O - Other	First Draw	ND
3c	Lower Level Locker Room	DF - Drinking Fountain	Flush	ND
4a	Outside Gym - Left	DF - Drinking Fountain	First Draw	ND
4b	Outside Gym - Bottle Filler	O - Other	First Draw	ND
4c	Outside Gym - Left	DF - Drinking Fountain	Flush	ND
5a	Outside Gym - Right	DF - Drinking Fountain	First Draw	ND
5b	Outside Gym - Right	DF - Drinking Fountain	Flush	ND
6a	Kitchen Prep Sink - Left	KS - Kitchen Sink	First Draw	2.30 ppb
6b	Kitchen Prep Sink - Left	KS - Kitchen Sink	Flush	ND
7a	Kitchen Prep Sink - Middle	KS - Kitchen Sink	First Draw	ND
7b	Kitchen Prep Sink - Middle	KS - Kitchen Sink	Flush	ND
8a	Kitchen Prep Sink - Right	KS - Kitchen Sink	First Draw	ND
8b	Kitchen Prep Sink - Right	KS - Kitchen Sink	Flush	ND
9a	Special Education Hallway	DF - Drinking Fountain	First Draw	2.69 ppb
9b	Special Education Hallway	DF - Drinking Fountain	Flush	2.11 ppb
10a	Special Education Room	S - Sink	First Draw	ND
10b	Special Education Room	S - Sink	Flush	ND
11a	2nd Floor Corridor - East	DF - Drinking Fountain	First Draw	ND
FHS-11b	2nd Floor Corridor - East	DF - Drinking Fountain	Flush	ND
FHS-12a	2nd Floor Corridor - West	DF - Drinking Fountain	First Draw	ND
FHS-12b	2nd Floor Corridor - West	DF - Drinking Fountain	Flush	2.40 ppb
FHS-13a	3rd Floor Corridor - West	DF - Drinking Fountain	First Draw	3.17 ppb
FHS-13b	3rd Floor Corridor - West	DF - Drinking Fountain	Flush	3.19 ppb
FHS-14a	3rd Floor Corridor - East	DF - Drinking Fountain	First Draw	ND
FHS-14b	3rd Floor Corridor - East - Bottle Filler	O - Other	First Draw	ND
FHS-14c	3rd Floor Corridor - East	DF - Drinking Fountain	Flush	ND

ND = None Detected

